

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	NOARK Electrics (Shanghai) Co.,Ltd.	Other Name	
Address	3857 Sixian Road Songjiang District Shanghai - China		
Client ID	107480	Global-Mark File Number:	107480-004
Certificate Number & Approval Mark	GMA-515475-EA	Revision Number	00
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	5/05/2023
Certificate Last Update Date	
Certification Expiry Date	5/05/2028

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC500V; type C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C13	Ui:1000V,Uimp:4kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C16	Ui:1000V,Uimp:4kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C20	Ui:1000V,Uimp:4kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C25	Ui:1000V,Uimp:4kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C32	Ui:1000V,Uimp:4kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C40	Ui:1000V,Uimp:4kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C50	Ui:1000V,Uimp:4kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V C63	Ui:1000V,Uimp:4kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC250V; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 1P DC250V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 2P DC500V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC750V; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 3P DC750V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K13	Ui:1000V,Uimp:4kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K16	Ui:1000V,Uimp:4kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K20	Ui:1000V,Uimp:4kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K25	Ui:1000V,Uimp:4kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K32	Ui:1000V,Uimp:4kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K40	Ui:1000V,Uimp:4kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K50	Ui:1000V,Uimp:4kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	Ex9BP 4P DC1000V K63	Ui:1000V,Uimp:4kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC250V; type C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC250V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC500V; type C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC500V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V C63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC750V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C13	Ui:1000V,Uimp:4kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C16	Ui:1000V,Uimp:4kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C20	Ui:1000V,Uimp:4kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C25	Ui:1000V,Uimp:4kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C32	Ui:1000V,Uimp:4kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C40	Ui:1000V,Uimp:4kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C50	Ui:1000V,Uimp:4kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V C63	Ui:1000V,Uimp:4kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC1000V; type C
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 1P DC250V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC250V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC500V; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 2P DC500V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC500V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K13	Ui:1000V,Uimp:6kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K16	Ui:1000V,Uimp:6kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K20	Ui:1000V,Uimp:6kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K25	Ui:1000V,Uimp:6kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K32	Ui:1000V,Uimp:6kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K40	Ui:1000V,Uimp:6kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K50	Ui:1000V,Uimp:6kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC750V; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Certificate of Conformity

Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 3P DC750V K63	Ui:1000V,Uimp:6kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC750V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K10	Ui:1000V,Uimp:6kV,In:10A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K13	Ui:1000V,Uimp:4kV,In:13A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K16	Ui:1000V,Uimp:4kV,In:16A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K20	Ui:1000V,Uimp:4kV,In:20A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K25	Ui:1000V,Uimp:4kV,In:25A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K32	Ui:1000V,Uimp:4kV,In:32A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K40	Ui:1000V,Uimp:4kV,In:40A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K50	Ui:1000V,Uimp:4kV,In:50A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K
Miniature overcurrent circuitbreaker	Moulded Case Circuit Breaker	NOARK	ExBP E 4P DC1000V K63	Ui:1000V,Uimp:4kV,In:63A;Ics=6kA, Icu=6kA; Ue:DC1000V; type K

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia

